

<b>Section No.</b>	<b>Interpretation</b>	<b>Effect</b>
308.5.1	If (5) or fewer adults are served less than 24 hrs./day the occupancy classification can be R-3 (a Residential occupancy).	A maximum of (10) adults could be served.
	<i>While there are some benefits to an R-3 classification (like not requiring sprinklers) I have assumed you would not want to take this route because of the low number of people you would be limited to serving.</i>	
308.5.1	If more than (5) adults are served less than 24 hr./day the occupancy classification must be I-4 (an Institutional occupancy).	
422.1.3	All walls and ceilings in rooms used for daycare and part of the exit pathway must have non-combustible (gypsum board or plaster) surfaces.	Approximately 996 s.f. of walls in Bldg. A must be clad with gypsum board.
903.2.5	Sprinklers are required throughout any building with a Group I Fire Area.	Both buildings must be sprinklered. This will require at min. a 4" water line and backflow preventer.
907.2.6	Fire alarm system required.	Both buildings must be equipped with fire alarm systems.

Woodhill Drive  
 1, North Carolina 27959